



Purchasing Department
530 Water Street
Oakland, CA 94607

December 5, 2016

ADDENDUM No. 1

Bid No. 16-17/08, Medium Voltage Metal-Clad Switchgear

This Addendum modifies the original Bid Documents for the above referenced Bid. **Acknowledge receipt of this addendum in the space provided on the Bid Form (Attachment 2).**

The following question was submitted by the deadline and is answered in this addendum:

1. Question: Part 2 – Products, A. (lists acceptable manufacturers), and I see no exceptions noted. At the Pre-Bid meeting, it was mentioned that the equipment needs to be Squared D, VR, 15 kV equipment. I represent Eaton, Cutler-Hammer as my primary line. I am attempting to partner with an integrator who can provide Square D. I have received no positive responses yet and want to know if an Equal solution will be acceptable. It will also meet all of the specifications. I have secured the required measurements to provide a bid.

Answer: Please refer to Plans and Specifications in their entirety. The requirements for the medium-voltage AC circuit breakers is described in the Plans and Specification 16342, Section 2.05. The medium-voltage AC circuit breakers must be Square-D, VR-15050-12, no substitutions allowed.

There are no other questions to Bid No. 16-17/08.